

Annexure C

PROFORMA FOR SAFE DRINKING WATER AND SANITARY CONDITION CERTIFICATE

No. UPJNR/C/P/393/2025-26

Dated: 19/03/20226

It is certified that an inspection team headed by Mr Surendra Pratap Singh (A.E.) (Name of Officers with designation) from U.P. Jal Nigam (Rural), Lucknow, inspected the **Rising Sun Wisdom School, Maurawan Road, Mohanlalganj, Lucknow** (Name & Address of the school) on 10/03/2026 (date of inspection) and on the basis of Water Test Report(Attached) bearing no UPJNR/C/P/393/2025-26 dated 19-03-2026 of **Regional Level Water Analysis Laboratory (UP JAL NIGAM)** certified that the **Rising Sun Wisdom School, Maurawan Road, Mohanlalganj, Lucknow** (Name of school) has safe drinking water facilities for the students and members of staff of the institution. School also maintains the hygienic sanitation condition in the school building & the campus as per norms prescribed by the Central/ State/ U.T. Govt.

This certificate is valid till 1 year from issue date

Signature with Seal:


Surendra Pratap Singh
Asstt. Engineer..
Division Office
Jal Nigam (Rural), Lucknow

Name: Mr Surendra Pratap Singh

Designation: Assistant Engineer

Name & Address of the Office / Department:

Regional Level Water Analysis Laboratory

To

**Rising Sun Wisdom School,
Maurawan Road, Mohanlalganj,
Lucknow**



Analysis Report

District Level Water Analysis Laboratory, U.P. Jal Nigam,(Rural),Lucknow



Rt.No. UPJNR/C/P/393/2025-26 Date: 19-03-2026 S.No : 393 Page No 1 page 1/1

Customer Details

Office Name and Address RISING SUN WISDOM SCHOOL , Maurawan Road,Dhanwara,Mohanlalganj, Lucknow -226301.
Ref Letter No & Date RSWs/05/2026 & 10-03-2026

Basic Details Of Sample

District	Lucknow	Block	Mohanlalganj
Gram Panchayat	Maurawan Road,Dhanwara	Village	Dhanwara
Habitation	Maurawan Road,Dhanwara	Location	School
Water Source	Tap water	Sample No.	2
Quality of Sample	1000ml	Date of S.C.	10-03-26
Receiving Date	10-03-26	S. Collector	Self
Sample Depositer	Self		
Analysis Start Date	11-03-26	Analysis Completion Date	18-03-26

Environmental Condition

Temperature	25± 3°C	Relative Humidity	Upto 65%
-------------	---------	-------------------	----------

Technical Data of Analysis

S.No.	Analysed parameters	Unit of Measurement	Observed Value	Specified Values as per IS 10500:2012		Ref. Method of Analysis
				Acceptable Limit	Permissible Limit in absence of alternate source	
1	2		3	4	5	6
1	Odour	-	NA	Agreeable	Agreeable	IS 3025 (Part 05) : 2018
2	Taste	-	NA	Agreeable	Agreeable	IS 3025 (Part 08) : 2023
3	Colour	HZ	1	5	15	IS 3025 (Part 04) : 2021
4	pH @ 22.7° C		6.682	6.5-8.5	6.5-8.5	IS 3025 (Part 11) : 2012 (RA :2022)
5	Turbidity	NTU	0.011	1.00	5.00	IS 3025 (Part 10) : 2023
6	TDS	mg/L	101	500	2000	IS 3025 (Part 16) : 2023
7	Chloride	mg/L	18	250	1000	IS 3025 (Part 32) : 2014 (RA : 2019)
8	Total Alkalinity	mg/L	20	200	600	IS 3025 (Part 23) : 2023
9	Total Hardness	mg/L	28	200	600	IS 3025 (Part 21) : 2019
10	Calcium as (Ca)	mg/L	6.412	75	200	IS 3025 (Part 40) : 2024
11	Sulphate	mg/L	1.362	200	400	APHA 24th Edition-45-SO4 Method E (Turbidimetric Method)
12	Magnesium as (Mg)	mg/L	21.587	30	100	IS 3025 (Part 46) : 2023
13	Fluoride	mg/L	0.146	1	1.5	APHA 24th Edition- 4500-F method C (Electrode Method)
14	Nitrate	mg/L	BDL	45	45	APHA 24th Edition -4500-NO3 Method B (UV Screening Method)
15	Iron	mg/L	0.004	1.00	1.00	APHA 24th Edition -3500-Fe Method B (Phenanthroline Method)

- Note-
1. This Certificate refers only to the particular sample(s) submitted for testing.
 2. This certificate shall not be reproduced, except in full, unless written permission for the publication of an approved abstract has been obtained from Head of Laboratory.
 3. The test results reported in this certificate are valid at the time of and under the stated conditions of measurements.
 4. Sample will be stored up to 15 days (in case of non perishable items only) from the date of issue of tests reports unless otherwise specified.
 5. Sample Collection was submitted by the customer, It's only Tested in Laboratory.
 6. The Result apply to the Sample as Received.

Authorized Signatory

Quality Manager
19/03/2026
Sonam Sharma
Technical Manager

** End Of Test Report **



Analysis Report
District Level Water Analysis Laboratory,
U.P. Jal Nigam,(Rural),Lucknow



Rt.No. UPJNR/B/P/393/2025-26 Date: 19-03-2026 S.No : 393 Page No 1 page 1/1

Customer Details

Office Name and Address RISING SUN WISDOM SCHOOL , Maurawan Road,Dhanwara,Mohanlalganj, Lucknow -226301.
Ref Letter No & Date RSWS/05/2026 & 10-03-2026

Basic Details Of Sample

District	Lucknow	Block	Mohanlalganj
Gram Panchayat	Maurawan Road,Dhanwara	Village	Dhanwara
Habitation	Maurawan Road,Dhanwara	Location	School
Water Source	Tap water	Sample No.	2
Quality of Sample	1000ml	Date of S.C.	10-03-26
Receiving Date	10-03-26	S. Collector	
Sample Depositer			
Analysis Start Date	11-03-26	Analysis Completion Date	18-03-26

Environmental Condition

Temperature	25± 3°C	Relative Humidity	Upto 65%
-------------	---------	-------------------	----------

Technical Data of Analysis

S.No.	Analysed parameters	Unit of Measurement	Observed Value	Specified Values as per IS 10500:2012		Ref. Method of Analysis
				Acceptable Limit	Permissible Limit in absence of alternate source	
1	2		3	4	5	6
1	E. Coli	CFU/100ml	0	Shall not be detectable in any 100 ml sample	No Relaxation	MFT
2	T. Coliform	CFU/100ml	0	Shall not be detectable in any 100 ml sample	No Relaxation	MFT

(Lovely Singh)
Microbiologist

Authorized Signatory

(Sonia Sharma)
Technical Manager

** End Of Test Report **

Laboratory Contact details-Email- upjallucknow@gmail.com